

SWISS COMPETENCE CENTER for ENERGY RESEARCH

SCCER-SoE Annual Conference 2016

In cooperation with the CTI

Swiss Competence Centers for Energy Research

Schweizerische Eidgenossenschaft Confédération suisse Confederazione Svizzera Confederaziun svizra

Swiss Confederation

Commission for Technology and Innovation CTI

Experimental investigation of a pump-as-turbine (PAT) to recover the energy lost in drinking water networks

V. Hasmatuchi, S. Luisier, C. Cachelin, C. Münch-Alligné

Q [m³/h]

Objective

SUPPLY of ELECTRICITY


The project focuses on the experimental investigation of a standard multi-stage pump used as turbine to recover the energy lost in a relief valve of a drinking water supply network.

Main project steps:

Measured characteristic curves (turbine mode)


✓ Operating range:

- Q = 10 ÷ 55 m³/h
 H = 0 ÷ 146 m
- ✓ Best efficiency point:
 n_{BEP} = 2'650 rpm




n [rpm]

- Study of installation of a pump-as-turbine along with a regulation valve on the Savièse (Switzerland) pilot site;
- Design and manufacturing of two possible setting configurations (in series and in parallel), including a relief valve, a pump-as-turbine and a regulation valve;
- Experimental measurements campaign on the parallel version installed in the HES-SO Valais//Wallis universal hydraulic test rig.



- $Q_{BEP} = 47.5 \text{ m}^3/\text{h}$
- H_{BEP} = 115 m
- $P_{elec BEP} = 8'500 W$
- η_{BEP} = 56 %
- ✓ Maximum power point:
 - n_{Pelec max} = 3'000 rpm
 - $Q_{Pelec max} = 52.6 \text{ m}^3/\text{h}$
 - $H_{Pelec max} = 136 m$
 - P_{elec max} = 11'250 W
 η_{Pelec max} = 55.7 %



P_{elec} = f(n,Q) - Pompelnversée - Mode Turbine

Experimental setup and instrumentation

- \checkmark Main components of the system:
 - Ebara EVMG32 5-0F5/11 pump as turbine DN65, 5-stages
 - Leroy-Sommer LSRPM 132 M generator 15.8 kW, 3000 rpm
 - ClaVal 90-G1E-01/KCOS relief valve DN100
 - ClaVal PCM 49E-G1E-93/H1/KCOSX pressure reducing valve with actuated pilot – DN100
- ✓ Connection scheme: "parallel" similar with the one of the pilot site
- ✓ Instrumentation:
 - Performed in accordance with the IEC 60193 standard
 - List of main employed instruments:


Measured quantity	Sensor type	Range	Precision
Discharge, Q	Electromagnetic flowmeter	0±60 [m³/h]	± 0.5 [%]
Head, H	Differential pressure sensor	016 [bar]	± 0.1 [%]
Setting level, H _s	Differential pressure sensor	05 [bar]	± 0.2 [%]
Absolute static pressure, M _{1, 2, 3}	Capacitive pressure transducer	010/20 [bar]	± 0.05 [%]
Electrical power, P _{elec}	Electrical multimeter	01000 [V _{trms}] 032 [A _{trms}]	± 0.03 [%]
		UJZ [A _{trms}]	


Main characteristics of the Savièse pilot site

- ✓ Gross head: 192 m
- ✓ Net head at maximum discharge: $H_{net} = 37$ m
- ✓ Maximum discharge: 97.2 m³/h

n [rpm]


✓ Half-time available conditions:





Turbine rotational speed, nUVW incremental encoder0..6000 [rpm]





Savièse project partners



Réservoir haut

4096 [ppr]



